

Inspection Checklist

Final Inspection

- Address numbers (visible and reflective)
- Exterior Lights (must meet lighting ordinance, fully shielded and downward facing)
- Propane tank signed off by fire department
- Propane detector installed
- All State sign offs done (hvac, electrical, plumbing)
- Door between house and garage must be self-closing and fire rated
- Smoke alarms/co detectors
- Bathroom fans
- Stairs (confirm riser height, tread depth and head height)
- Grab rails
- Guard rails
- Attic and Crawl Insulation
- Filled out insulation sticker
- Tempered Glass
- Bathroom clearances
- Crawl space (recheck)
- Exterior doors (landings and steps)
- Siding and soffit (complete)
- Final grading